

AHC Behavioral Health Response to Cabling RFP Questions

- Can you send Exhibit -A CDs. **CD's have been sent.**
- Can you confirm if data is needed for any of the TV locations with triangles? **Only the Tele-Psych room and the flex space TV locations require data. Each location should receive 2D in a separate outlet bxx near the TV symbol.**
- Any cable needs for icon "MS" at the Nurse Station? **The "MS" icon for Nurse Call. This cabling will be installed by others.**
- E100 TV Symbol shows 1 Cat6/1RG6. Is there a Cat6 and what trade is responsible for each cable? **The RG-6 cable for each TV location will be installed by others. There will not be a need for data cables at any TV locations other than the Tele-Psych room and the Flex Space which will require 2D in separate boxes near those TV locations.**
- E401 TV Symbol in Pat. Bays 1Cat6/1RG6. Do the Pat Bays get both of these cables? **The Patient Bay TVs do not need a data connection. The RG-6 will be installed by others.**
- E401 PC Symbol in Pat. Bays show a data triangle. Is there a cable for these symbols? The "PC" symbol is for a nurse call device. **This cabling to be installed by others.**